

No: PH/Water/BAC/509/2026 27
508

GOVERNMENT OF KARNATAKA

Office of Joint Director
Public Health Institute,
Bengaluru - 560001

Report of Bacteriological analysis of Water Sample

Date: 24/05/2026.

Sample No	Source & Particulars of Water Sample	Opinion					
		M.P.N. Count	Plate Count	D.C. Test	S.P.P	N.S.P.P	N.S.P.P & FC
1551	Drinking water.	Nic	-	-	SPP	-	-

Note:
M.P.N. Count:
Most Potable number of Bacteria Per 100ml of Water
D.C Test:
Differential Coliform test
Plate Count:
Plate Count per ml of sample
SP:
Water is satisfactory for Potable purpose
NSPP:
Water is not satisfactory for Drinking purpose
NSPP & FC:
Water is not satisfactory for Drinking purpose and E. Coli found


Principal

Ryan International Academy
#5, Bhole Farms, Magadi Main Road
Kempagowda Nagar, Byadarahalli
Hosahalli Golarapalya, Bengaluru-560091


Manager-Administration

RYAN INTERNATIONAL ACADEMY
5, Bhole Farms, Hosahalli Golarapalya,
Magadi Main Road, Kempa Gowda Nagar,
Byadarahalli, Bengaluru, Karnataka-560091

For Joint Director (Labs) Microbiologist
PUBLIC HEALTH INSTITUTE (Senior Specialist)
Public Health Institute
Bengaluru-560 001
Bengaluru

ANNEXURE 1 (2007 to 2010)

10/10/07 - 10/10/07

Advice: 1. Sample

Need effective chlorination before

2. Sample

Need to avoid possible source of faecal contamination and effective chlorination before use for the purpose of Chlorination. Refer the Annexure enclosed.

STANDARD FOR THE DRINKING WATER

		Presumptive Coliform Count Per 100 ml	E Coli Count Per 100 ml
CLASS 1	Excellent	0	0
CLASS 2	Satisfactory	1-3	0
CLASS 3	Suspicious	4-10	0
CLASS 4	Unsatisfactory	Greater than 10	0.1 or More